



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 8

1595 WYNKOOP STREET
DENVER, COLORADO 80202-1129
Phone 800-227-8917
<http://www.epa.gov/region08>

2007 SEP -7 AM 9:28

Ref: 8ENF-W

SEP - 7 2007

CERTIFIED MAIL RETURN RECEIPT REQUESTED

Dale and Amanda Eckdahl
Mountain High Resorts, Inc.
WyColo Lodge
4039 Hwy 230
Laramie, WY 82070

Re: Emergency Order Closure
Docket No. SDWA-08-2007-0044
PWS ID #5601558 WyColo Lodge

Dear Mr. and Mrs. Eckdahl:

This letter is to inform you of the Environmental Protection Agency's (EPA) decision to close the Emergency Order, Docket Number SDWA-08-2007-0044, issued to you and Mountain High Resorts, Inc., on April 4, 2007. Based on the information provided by your engineering firm, Weston Engineering, and the Wyoming Department of Environmental Quality, that the system has a new well, provides disinfection, and a cross connection survey has been completed and identified issues remedied, EPA will close the Emergency Order.

Please be aware that you are still required to comply with the National Primary Drinking Water Regulations (NPDWR), 40 C.F.R. Part 141. Violation of the NPDWRs or an administrative order may subject you to a court-imposed injunction and penalties of up to \$32,500 per day of violation.

We appreciate your cooperation. If you have any questions regarding this matter, please contact Kathelene Brainich, Environmental Protection Specialist, at (303) 312-6481. If you have legal questions, please ask your attorney to call Peggy Livingston, Enforcement Attorney, at (303) 312-6858.

Sincerely,

Lisa Kahn, Team Lead
Drinking Water Enforcement Program
Office of Enforcement, Compliance
and Environmental Justice

cc: Janet L. Tyler, Attorney
Sue Ann Spencer, Weston Engineering
WY DEQ & WY DOH (via email)



Printed on Recycled Paper